

FESHM 5031.4: Inspection and Testing of Relief Systems

Revision History

Author	Description of Change	Revision Date
Thomas Page	Revised definition of “primary relief devices”; changed “external inspection” to “visual inspection”.	December, 2011
Thomas Page	Added chapters 5031.1 and 5031.6 to the scope of the chapter. Revised wording in Section 3.3.	January, 2011

	Fermilab ES&H Manual	FESHM 5031.4 December 2011
---	---------------------------------	-------------------------------

TABLE OF CONTENTS

1.0	INTRODUCTION.....	3
2.0	DEFINITIONS	3
3.0	RESPONSIBILITIES	4
3.1	Division/Section/Center Head	4
3.2	The Mechanical or Cryogenic Safety Subcommittee(s).....	4
3.3	The ES&H Section	4
4.0	PROCEDURE	4
5.0	FORMS	5

	Fermilab ES&H Manual	FESHM 5031.4 December 2011
---	---------------------------------	-------------------------------

1.0 INTRODUCTION

Relief systems must be periodically inspected and maintained in order to assure proper operation. This chapter specifies an inspection and testing program for all pressure relief systems that are required under the provisions of the Fermilab ES&H Manual Section 5031, 5031.1 and 5031.6. This chapter applies to non-code stamped parallel plate relief devices typically used on vacuum vessels and insulating vacuum spaces covered by FESHM 5033. This chapter applies to non-code stamped relief valves used on low pressure (less than 15 psig) vessels covered by FESHM 5031.5

2.0 DEFINITIONS

Primary Relief Devices - those that are required by the provisions of the Fermilab ES&H Manual Section 5031, 5031.1, 5031.5, 5031.6, and 5033. Trapped volume relief devices are not considered primary relief devices unless they serve as the primary relief device for the system.

Primary Relief Systems - primary relief devices and their inlet and outlet piping.

Protected System - the piping, vessel, or system of piping and vessels for which the primary relief system is required.

Visual Inspection - consists of verifying, to the extent possible without disassembling the relief system or removing relief devices, that:

- a. The relief devices are the same as those described in Engineering Notes,
- b. The outlet or discharge piping of relief devices has remained unrestricted,
- c. The inlet and outlet piping of the relief system have not been changed in a way that would reduce the relief capacity given in Engineering Notes, and
- d. The relief devices have not undergone severe corrosion or tampering.

Testing of a Re-Closing Relief Device - verifying that the set pressure satisfies the requirements of ASME Code Section VIII Division 1 paragraphs UG-126 and UG-134 or Division 2 Article R-1 for code stamped relief valves or other Codes/Standards as required by the affected Engineering Note. For non-code stamped relief valves used on low pressure or vacuum vessels, use engineering judgment to in determining if the set pressure and valve opening are appropriate for the service conditions.

- a. The relief device may be tested in place provided the test pressure does not exceed the maximum allowable working pressure of the protected system; otherwise, the relief device must be removed for testing.

	Fermilab ES&H Manual	FESHM 5031.4 December 2011
---	---------------------------------	---

3.0 RESPONSIBILITIES

Responsibilities are as follows.

3.1 Division/Section/Center Head

The Division/Section Head who controls the area of operation of the protected system is responsible for carrying out the requirements of this chapter. He/She is responsible for maintaining a database of relief valve information and updating whenever a relief valve is changed, added, inspected, or removed from service for relief valves on systems within the division or section.

3.2 The Mechanical or Cryogenic Safety Subcommittee(s)

The Mechanical or Cryogenic Safety Subcommittee(s) will serve in a consulting capacity to division/section heads in all matters concerning the inspection and testing of relief systems.

3.3 The ES&H Section

The ES&H Director shall, as editor and distributor of the Fermilab ES&H Manual, assure approved policies and procedures developed by the Laboratory Environment, Safety and Health Committee (FESHCom) and its technical subcommittees, ES&H professionals, and "ad hoc" groups have been incorporated into the Fermilab ES&H Manual (FESHM). The ESH Section may conduct Independent Assessments (assessments that are scheduled outside the Tripartite Assessment process) of FESHM chapters. Such supplemental assessments may be motivated by an incident, a perceived weakness in an ES&H program, or by a new ES&H requirement.

4.0 PROCEDURE

1. Visual Inspection: A visual inspection of each relief system must be made prior to initial operation of the protected system. The inspection must be repeated at regular intervals. The maximum interval between inspections may not exceed three years.

2. Testing of Primary Relief Devices:

- a. Re-closing primary relief devices must be tested prior to their installation. The testing must be repeated at regular intervals. The maximum interval between tests may not exceed six years. In the case of new and not previously used relief devices, certification of the set pressure by the manufacturer will be considered to constitute a test. In this case, the test date will be considered to be the date on which the relief device was delivered at Fermilab and the requirement for further testing prior to installation will be waived.

	Fermilab ES&H Manual	FESHM 5031.4 December 2011
---	---------------------------------	--------------------------------------

- b. Non-re-closing (burst disk) and parallel plate primary relief devices (used on vacuum vessels and insulating vacuum spaces) need not be tested, but must be inspected every three years.
- c. If a protected system is provided with n sets of primary relief devices, each of the sets individually satisfies all Fermilab ES&H Manual requirements, and each of the sets is always connected to the protected system, then the interval between tests specified in 2.a. may be extended to n times six years.

3. Corrective Actions: Immediate corrective actions must be taken if any inspection indicates that a primary relief device may not operate properly. The actions must ensure that the failure of the relief device to operate properly will not result in a safety hazard.

4. Records: A record of the inspections and tests of each primary relief system and each primary relief device shall be maintained by the person responsible for the protected system. These records shall contain vessel / system identification numbers, relief device specifications, and such documents as are necessary to record the results of inspections, repairs, alterations, or re-ratings of the relief system and devices. These records should be retained and preferably attached to a copy of the relevant Engineering Note(s). A suggested format of the Relief Device Maintenance/Test Record is referenced in Section 5.

5. Existing Systems: If an existing primary relief system is found not meeting this chapter, immediate corrective actions must be taken ensure safety. This may include taking the system out of service or incorporating administrative controls to assure safety until the system can be brought into compliance. Thereafter, the inspection and testing intervals specified in 1 and 2 apply.

5.0 FORMS

The Relief Device Maintenance/Test Record form can be found on the ES&H Section website.